

---

## Asbestos Analysis Report

---

**Report No :** J118602 **Sample Batch** 1-1  
**Client :** Peter Shah **Client Ref:**  
**Location :** Scimart Ltd, Unit 1 Vauxhall  
Business Centre, Vauxhall  
Industrial Estate, Ruabon, LL14  
6HA  
**Samples Taken :** 5 September 2018 **Report Issued:** 5 September 2018

---

Sample No.	Source	Result	Material (see Note(3))
Sample 1	Wire Gauze	No Asbestos Detected	Board

---

---

**Test Method:** Polarised light microscopy; Dispersion staining, in accordance with HSG248

---

**Note (1):** PC laboratory analysis of samples and sampling procedures are in compliance with ISO 17025 and our UKAS accreditation.

**Note (2):** Where PC staff have not taken samples (indicated by "Samples Received" or "Samples Collected"), results given are based on information supplied by the client taking the samples. PC is not responsible for any errors/misinterpretations of analytical results due to inappropriate sampling strategies or techniques.

**Note (3):** Observations and interpretations expressed (i.e. nature of fibres other than asbestos or description of material) are outside the scope of our UKAS accreditation.

---

Types of Asbestos
Amosite - Brown Asbestos
Chrysotile - White Asbestos
Crocidolite - Blue Asbestos

**ANALYST:**



---

Oliver Rix